

If you are subject to the alternative language notice requirements in 30 Texas Administrative Code §39.426, **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Bright Star-Salem Special Utility District (CN603040486) operates Bright Star-Salem Surface WTP RN:108273038. a Special Utility District. The facility is located at 2124 Farm-to-Market Road 2946, in Emory, Rains County, Texas 75440.

Renewal to discharge 35,000 gallons per day of treated domestic wastewater

Discharges from the facility are expected to contain Total Suspended Solids, Total Dissolved Solids, pH, Fluoride, Aluminum, Alkalinity. Domestic Wastewater is treated by *backwash water from the surface water treatment facility enters the lagoon the solids settle to the bottom for sludge removal and the water overflow is measured through a V-notch weir and sampled weekly for Total Suspended Solids and monthly for pH, annually excess sludge is removed from the lagoon and land applied through a private contractor with land application permit.*