

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in 30 Texas Administrative Code §39.426, **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Springlake-Earth ISD (CN600661102) operates Springlake-Earth ISD Wastewater Treatment Plant (RN101219285). a domestic wastewater treatment facility utilizing a septic tank. The facility is located 0.5 miles west of the intersection of FM Road 302 and 2901, in Springlake-Earth, Lamb County, Texas 79031.

12,000 GPD wastewater treatment plant treats domestic wastewater for Springlake-Earth ISD. This permit will not authorize a discharge of pollutants into water in the state.

Discharges from the facility are expected to contain BOD₅. Domestic wastewater will be treated by a 15,000 gallon septic tank and pumped directly to a storage pond. The effluent will then be land applied on 14 acres of haygrazer/wheat.

PLANTILLA EN ESPAÑOL PARA SOLICITUDES NUEVAS/RENOVACIONES/ENMIENDAS