

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Lavaca-Navidad River Authority (CN600624175) operates Lake Texana Plant No.1 Wastewater Treatment Facility RN101609881. a domestic wastewater treatment facility. The facility is located at 891 Brackenridge Parkway, in Edna, Jackson County, Texas 77957.

Request for renewal of permit authorizing the discharge of 50,000 GPD of treated domestic wastewater.

Discharges from the facility are expected to contain BOD (5), Total Suspended Solids and E. coli. Domestic wastewater is treated by an activated sludge plant operated in the extended aeration mode with enhanced secondary treatment..

PLANTILLA EN ESPAÑOL PARA SOLICITUDES NUEVAS/RENOVACIONES/ENMIENDAS TPDES o TLAP

AGUAS RESIDUALES DOMÉSTICAS