

Section 15. Plain Language Summary (Instructions Page 40)

If you are subject to the alternative language notice requirements in [30 Texas Administrative Code §39.426](#), **you must provide a translated copy of the completed plain language summary in the appropriate alternative language as part of your application package.** For your convenience, a Spanish template has been provided below.

ENGLISH TEMPLATE FOR TPDES or TLAP NEW/RENEWAL/AMENDMENT APPLICATIONS

DOMESTIC WASTEWATER

The following summary is provided for this pending water quality permit application being reviewed by the Texas Commission on Environmental Quality as required by 30 Texas Administrative Code Chapter 39. The information provided in this summary may change during the technical review of the application and are not federal enforceable representations of the permit application.

Twinwood (U.S.) Inc (CN601122252) proposes to operate Ranch 359 Wastewater Treatment Facility RN102806718. a wastewater treatment facility. The facility will be located approximately 0.5 miles south of the intersection of Farm-to-Market Rd 359 and Church Road , in Brookshire, Waller County, Texas 77423.

This application is for a renewal to discharge at an annual average flow of 750,000 gallons per day of treated domestic wastewater via a 30-inch outfall into Brookshire Creek, thence to Bessie Creek, thence to Brazos River below Navasota River Segment No. 1202 of the Brazos River Basin. *<<For TLAP applications include the following sentence, otherwise delete:>>* This permit will not authorize a discharge of pollutants into water in the state.

Discharges from the facility are expected to contain five-day carbonaceous biochemical oxygen demand (CBOD₅), total suspended solids (TSS), ammonia nitrogen (NH₃-N), and Escherichia coli. Domestic wastewater will be treated by an activated sludge process plant and the treatment units include a bar screen, aeration basins, final clarifiers, sludge digesters and chlorine contact chambers.